



Garcilaso, 4 Baixos
08201 Sabadell
935 959 560

laboratori@analisiisreig.cat
www.analisiisreig.cat

CERTIFICATE OF MICROBIOLOGICAL EFFICIENCY OF NUVOHLA ROOM/LIFT ON ENVIRONMENTAL AIR

Doctor ROSER REIG RIUS director of **INDUSTRIAL LAB R. REIG, S.L.** with CIF B65324238 and address Garcilaso 4 in Sabadell (Barcelona) Spain,

CERTIFIES:

That laboratory INDUSTRIAL LAB R. REIG, S.L. has evaluated the efficiency of the “**NUVOHLA ROOM/LIFT**” equipment that **AIRTECNICS, S.L.** commercializes, analysing the **ENVIRONMENTAL AIR**: total aerobic bacteria and fungi, before and after the environmental treatment with the already mentioned equipment.

According to the tests carried out in the laboratory INDUSTRIAL LAB R. REIG, S.L. the tested **Nuvohla Room/Lift** equipment has showed a **reduction rate** of the total environmental aerobic bacteria of **93,75%** and of the environmental fungi of **90%**, after 300 minutes of equipment operation.

The test procedures performed are standardized and based on proven scientific studies. Sampling and counting of bacteria and fungi is based on the UNE EN ISO 14698 standard: “Cleanrooms and associated controlled environments. Bicontamination control”.

Sabadell, January 25th 2022



Garcilaso, 4 Baixos
08201 Sabadell
935 959 560

Doctor Roser Reig

Director



Generalitat de Catalunya
Departament de Salut
LABORATORI DE SALUT AMBIENTAL
I ALIMENTÀRIA: LSAA-155-01



agencia española de
medicamentos y
productos sanitarios
LABORATORIO DE CONTROL



ÁREA DE CALIDAD SANITARIA DE LAS AGUAS. REGISTRADO
S. G. DE SANIDAD AMBIENTAL Y SALUD LABORAL